

Annexure- C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 262

Dated: 20/03/2026

It is certified that an inspection team headed by

Shri Ashok Kumar Dewagan (Name of Officers with designation)

from public Health Engg. sub Division Kurud PHED

inspected the

(Name & Address of the school) on 20/03/26 (date of inspection) and on the basis

of Water Test Report (Attached) bearing no.

dated 20/03/26 of PHED sub Division Kurud (PHED Lab)

certified that the

Dronacharya public school Amlidih (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 20/03/2027.

Signature with Seal: Assistant Engineer
Name : Public Health Engg. Sub Div.
Designation : Kurud, Distt. Dhamtarai C.G.
Name & Address of the Office / Department

To

Principal
Dronacharya public school, Amlidih
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

कार्यालय सहायक अभियंता
लोक स्वास्थ्य यांत्रिकी उपखण्ड कुरुद, जिला - धमतरी (छ.ग.)
क्रमांक 07 / स. अ. / लो.स्वा.या.उपखण्ड / 2025-26 / कुरुद, दिनांक 20/03/2026
प्रति ,

प्राचार्य
द्रोणाचार्य पब्लिक स्कूल अमलीडीह
वि.ख. मगरलोड , जिला धमतरी

विषय:- पानी जांच रिपोर्ट प्रदाय करने बाबत।

संदर्भ :- आपका पत्र क्र. DPS/26-27/003 दि. 18.03.2026

====00====

उपरोक्त विषयांतर्गत लेख है कि आपके द्वारा सम्पवेल की पानी, उपयोग किये जा रहे जल की गुणवत्ता जांच कर रिपोर्ट चाही गई थी। आपके द्वारा दी गई बोर का पानी का जांच कर रिपोर्ट आपकी ओर प्रस्तुत है।

संलग्न:- उपरोक्तानुसार जल परीक्षण रिपोर्ट।


सहायक अभियंता
लोक स्वास्थ्य यांत्रिकी
उपखण्ड कुरुद

Sub Division Level Water Testing Laboratory
Public Health Engineering Department Kurud Chhattisgarh
 Under Filter Plant, in front of KPS School Kurud
 E-Mail-kurudphe@gmail.com Phone-07705-223557
Test Report

Kind of Sample- Drinking Water	Report No.SDI/PHED/KRD		Sample Collected By -	Dusehan Kumar
Sender Name and Address :	Sender letter no..	-	Sender's Letter Date	-
Departmental Sample	Date Of Collection	19/03/2026	Sampling plan & Procedure No.	Not Done By Lab
	DL Receipt No.		DL Receipt Date	-
	Date Of Analysis Started	19/08/26	Date of Analysis Completed	26/08/26
No.	DISTRICT	BLOCK	VILLAGE	Location/Source
1	Dhamtari	Mageelad	Amlidih	Doonacharya public school. B06
2	Dhamtari			
3	Dhamtari			
4	Dhamtari			
5	Dhamtari			
6	Dhamtari			

Details of parameters , their test methods, unit and specification as per IS/APHA

Sl. No.	Characteristics	Test Method IS 3025		Unit of Measurement	As Per IS-10500:2012 for Drinking Water		Results							
		3	4		Acceptable Limit	Permissible Limit	1	2	3	4	5	6	7	8
1	2	3	4	5	6	7	8							
1	Color	IS 3025	Part -04	Hazen	5-15	No Relaxation	5	-	-	-	-	-	-	-
2	Odour	IS 3025	Part -05	-	Agreeable	Agreeable	Agreeable	-	-	-	-	-	-	-
3	Taste	IS 3025	Part -08	-	Agreeable	Agreeable	Agreeable	-	-	-	-	-	-	-
4	Turbidity	IS 3025	Part-10	NTU	1.0	5.0	0.32	-	-	-	-	-	-	-
5	Chloride as Cl ⁻	IS 3025	Part-32	mg/L	250	1000	70.35	-	-	-	-	-	-	-
6	TDS	IS 3025	Part-16	mg/L	500	2000	232	-	-	-	-	-	-	-
7	Total Alkalinity as CaCO ₃	IS 3025	Part - 23	mg/L	200	600	182.52	-	-	-	-	-	-	-
8	Calcium as Ca ⁺⁺	IS 3025	Part - 40	mg/L	75	200	59.67	-	-	-	-	-	-	-
9	Magnesium as mg ⁺⁺	IS 3025	Part - 46	mg/L	30	100	12.73	-	-	-	-	-	-	-
10	pH	IS 3025	Part - 11	pH Scale	6.5-8.5	No Relaxation	6.9	-	-	-	-	-	-	-
11	Total Hardness as CaCO ₃	IS 3025	Part - 21	mg/L	200	600	201.6	-	-	-	-	-	-	-
12	Iron	IS 3025		mg/L	0.3	1	0.12	-	-	-	-	-	-	-
13	Fluoride	IS 3025		mg/L	1.0	2	0.18	-	-	-	-	-	-	-
14	Coliform	IS 3025		MPN/100ml	0	0	NM	-	-	-	-	-	-	-
15	Residual Chlorine	IS 3025		mg/L	0.2	1.0	0.0	-	-	-	-	-	-	-
16	Conductivity	IS 3025		mg/L	500	2000	278.1	-	-	-	-	-	-	-

1 The report should not be produced partly or full without approval of singntory authority of legal purposes.

2 It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but upto the limits indicated under the "permissible limit Inthe absence of alternate source" In column 7 above wh ich the sources will have to be rejected.

3 The results refer only to tested samples and paramater tested

4 samples will be stored for a period of 10 days from date of Issue of report.

5 This lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.

6 The Laboratory does not hold any responsibility for variation in results for samples kept on hold for want of clarification.

Issue No. /DL/Date

Page No 01 to 01


 Authorised Signature
 Sub Dn Water Testing Laboratory
 PHED Kurud , Dhamtari (C.G.)